



تليفون : 4445363 / 44845306 / 44845306 (974) فاكس : 4445363

ص. ب : 41 الدوحة - قطر

Tel: (974) 44845306 / 44845363 Fax: (974) 44845363
P.O. Box: 41 Doha - Qatar

Ref. #TWS/LT/15/ 989
10/06/2015

SENIOR RESIDENT ENGINEER
KEO
P.O BOX: 18108
FAX: 44626500
DOHA-QATAR

PROJECT: DESIGN & CONSTRUCTION SERVICES ROAD ENHANCEMENT TO
NORTH ROAD CORRIDOR (P059) - IA 11/12 C159 G

SUBJECT: MATERIAL FOR APPROVAL

With reference to the above-captioned subject and to your letter ref. No. 11-5719-CM-P059-KEO-KHR-LT-SH-00031 dated 09.05.2015, please find our comment in the below table:

SR. NO.	Description	Manufacturer	Remarks
1	Fasteners Stainless Steel Grade 316L - Bolts, Nuts and Washers	M/s. Baseline Bolting Industries - U.A.E	Conditional Approval See Note 1 Below

Note 1: The propose materials are subject to having a chemical test result at the time of supply. Furthermore, random samples will be collected for test upon material delivery to site; test will be done at independent laboratory witnessed by KM Engineer. Cost will be borne by the supplier/contractor.

The above materials must comply with the KM General Specifications at the time of supply.

This is for your information and necessary action.

Regards,

ENG. MOHAMMED RASHID AL-KUWARI
A/HEAD, SECONDARY WATER PROJECTS

AY/TWS
WP/WMS/1955/2015 dt 09.06.15

