



تلفون : 44845383 فاكس : (974) 44845306 / 44845363  
 ص.ب : ٤١ الدوحة - قطر  
 Tel: (974) 44845383 / 44845363 Fax: (974) 44845383  
 P.O. Box: Al Doha - Qatar

Ref: # TWS/ILT/15/ 1347  
 12/08/2015

SENIOR RESIDENT ENGINEER  
 KAWSP  
 P.O. BOX: 10281  
 Tel. No:4467-1051/65  
 Fax No.:4465-7002  
 DOHA, QATAR

**PROJECT : IA-13-14/C/002/ST -- ROAD & INFRASTRUCTURE FOR COMMERCIAL STREET IN AL KHOR AREA (G2013/95)**

**SUBJECT: MATERIAL APPROVAL REQUEST**

With reference to the above mentioned subject and to your letter ref. No. QN003-P00-KWJ-KAW-LET-A10387 dated 05.07.2015, please find our comment in the below table:

SR. NO.	Description	Manufacturer	Remarks
1	Hex Bolts, Hex Nuts & Flat Washer Grade SS 316L/A4L (Size -M33,M30,M27,M20 & M16)	M/s. Baseline Bolting Industries LLC - UAE	Approved See Note 1 Below

NOTE: ACCORDING TO KWI SPECIFICATION, SECTION 1 (MODIFIED) IT IS CLEARLY SPECIFIED TO USE 316L STEEL HOT DIPPED GALVANIZED MINIMUM 70 MICRON THICKNESS OF COATING. UNLESS PROJECT SPECIFICATION CLEARLY SPECIFYING STAINLESS STEEL TYPE. CHEMICAL ANALYSIS REPORT OF DELIVERY ITEM TO BE SUBMITTED ALONG WITH THE INSPECTION REQUEST.

The above materials must comply with the latest KM General Specifications at the time of supply.

This is for your information and necessary action.

CC TO *[Handwritten initials]*  
 YCC

Regards,

**MOHAMMED RASHID AL-KUWARI**  
 HEAD, SECONDARY WATER PROJECTS

AM/TWS  
 WPA/WMS/2806/2015 dt 04.08.2015

**RECEIVED**  
 GCC  
 16 AUG 2015

By: *Moidu*

**RECEIVED**  
 K&A WSP  
 13 AUG 2015

**K&A WSP/ITV**

RECEIVED DATE:	13/08/15	T. No
DIST.	INITIAL	DATE
Jc	[Signature]	13/08
MOHAMMED [Signature]		INFO
[Signature]		ITV AD.
FILE REF: QN003-KAW-0094		
REPLY REF:		



better living

حياة أفضل